# H&V Lamella Roll MP631



### Technical Data Sheet

H&V Lamella Roll MP631 is designed for installation around heating and ventilation duct applications or vessels across both process and HVAC markets.

# PRODUCT

Designed to be used as thermal and acoustic insulation for H&V Pipes, Ducts and Vessels. Rockfibre in lamella form offers a higher level of compressive strength than standard insulation and gives integrity of thickness, particularly around corners of rectangular units.

The foil provides a high efficiency vapour barrier.

H&V Lamella Roll MP631 is wrapped around pipes, ducts or vessels and closely butted together with all joints sealed with foil tape.

#### Roll Dimensions:

- 10m 1200 x 25mm (12.00m<sup>2</sup>)
- 8m 1200 x 30mm (9.60m<sup>2</sup>)
- 6m 1200 x 40mm (7.20m<sup>2</sup>)
- 5m 1200 x 50mm (6.00m<sup>2</sup>)
- 4m 1200 x 60mm (4.80m<sup>2</sup>)
- 3m 1200 x 80mm (3.60m<sup>2</sup>)


Other sizes and densities are available to order.

# **SPECIFICATION**

- Excellent insulation performance
- High efficiency vapour barrier
- Easy to handle and install

## **Rockfibre Density**

33kg/m3, 45kg/m3 or 60kg/m3



H&V Lamella.



0161 447 8320
sales@mayplas.co.uk
www.mayplas.co.uk



www.PerformanceTechnologyGroup.com

IMPORTANT: Directions for use are given for guidance only and are not intended to form part of any contract. They should be varied or adapted to suit your particular materials or conditions of use. It is strongly recommended that prospective users test a sample of the product under their own conditions to satisfy themselves of its suitability for the intended purpose. For the Pre Completion Testing route to compliance with the Building Regulations Mayplas may provide site test evidence (where available) concerning the use of their product in a similar overall construction. Test evidence of a product passing minimum standards in one construction is not a warranty or specification that the same product will meet the desired acoustic performance level in any other building. Such evidence can only be considered indicative and should not be relied upon.